

CERTIFICATE OF COMPLIANCE

Certificate Number 20150123-E358319
Report Reference E358319-20130116
Issue Date 2015-JANUARY-23

Issued to: MERSEN FRANCE SB S A S
15 RUE DE VAUCANSON
69720 ST BONNET DE MURE FRANCE

**This is to certify that
representative samples of**

FUSES FOR PHOTOVOLTAIC SYSTEMS

Listed Nonrenewable fuses for use with photovoltaic applications Cat. Nos. HP10NH1GPV, HP12NH3LGPV, HP10NH2GPV, HP12NH1XLGPV, HP12NH2XLGPV, HP15NH3LGPV, followed by additional numbers that represents ampere rating, followed by B in case of bolted version.


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 248, Low-Voltage Fuses-Part 1: General Requirements.
UL 2579, Low-Voltage Fuses-Fuses For Photovoltaic Systems.

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

