OVE Austrian Electrotechnical Association Eschenbachgasse 9, 1010 Wien, Austria ZVR: 327279890 | DVR: 1055887

OVE Testing & Certification

Kahlenberger Str. 2A, 1190 Wien, Austria T +43 1 370 58 06 | F +43 1 370 58 06-199

www.ove.at



Page 1 of 2



including the entitlement to use the Austrian Safety Mark



Certificate No.: 25214-007-05

Valid from: 2018 12 16 until: 2020 12 16

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: Mersen France SB SAS 15 Rue Jacques de Vaucanson 69720 Saint Bonnet de Mure France

Product: Low-voltage fuse-rails

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s).: 2.03.02423.1.0/2.BSL/185

Österreichischer Verband für Elektrotechnik Head of Testing & Certification



Vienna, 2018 10 18

OVE Testing & Certification



Digitally signed by W. Martin Email=w.martin@ove.at

Dipl.-Ing. W. Martin





Certificate No.: 25214-007-05 Date: 2018 10 18 Page 2 of 2

Manufacturer:

Mersen France SB SAS 15 Rue Jacques de Vaucanson 69720 Saint Bonnet de Mure France

Factory location(s):

Mersen CZ s.r.o. Pardubická 437 53304 Sezemice Czech Republic

Tested and certified according to:

ÖVE/ÖNORM EN 60269-1:2015-06-01 ÖVE/ÖNORM E 8669-2:2014-11-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**.

Product: Low-voltage fuse-rails

Type designation: Rating:

2.BSL Rated voltage: 690 V Rated frequency: 50-60 Hz Rated current: 400 A Size 2 3-pole IP20 (by using fuse-links with gripping lugs of insulating material) Trademark:

MERSEN

OVE Testing & Certification



