

# TYPE APPROVAL CERTIFICATE

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the DNV GL Type Approval System.

Certificate No. **98 791 - 96 HH**

Company **Mersen France SB S.A.S.**  
**15 Rue Vaucanson**  
**69720 Saint Bonnet de Mure, FRANCE**

Product Description **D0 - fuse system**  
**D 01 ( part numbers 01700.xxxxxx ); D 02 ( part numbers 01701.xxxxxx )**

Type **D 01, D 02**

Environmental Category **C**

Technical Data /  
Range of Application

<b>D 01:</b>	<b>Rated voltage U:</b>	<b>440 V AC, 250 V DC</b>
	<b>Rated current I:</b>	<b>2, 4, 6, 10, 16 A</b>
	<b>Rated frequency f:</b>	<b>45 - 62 Hz</b>
	<b>Rated breaking capacity I:</b>	<b>50 kA</b>
	<b>Utilization category:</b>	<b>gL</b>
<b>D 02:</b>	<b>Rated voltage U:</b>	<b>440 V AC, 250 V DC</b>
	<b>Rated current I:</b>	<b>20, 25, 35, 50, 63 A</b>
	<b>Rated frequency f:</b>	<b>45 - 62 Hz</b>
	<b>Rated breaking capacity I:</b>	<b>50 kA AC, 8 kA DC</b>
	<b>Utilization category:</b>	<b>gL</b>

**Accessories as listed in technical data sheet**

Test Standard **EN 60269-1:2007 +A1: 2009; HD 60269-3: 2010**

Documents **Test report EPM: 76 083 3, 76 049 2**  
**Technical data sheet: Lindner 1408.3.95; VDE 40016023; VDE 40016013; VDE 40016014**

Remarks **This certificate is issued on the basis of GL Guidelines for the Performance of Type Approvals, Chapter 1 - Procedure (VI-7-1), Edition 2007**

Valid until **2020-02-19**  
Page **1 of 1**  
File No. **I.L.08**  
**Hamburg, 2015-02-20**

Type Approval Symbol



i.A.  
Arne Schaarmann

i.A.  
Thomas Hartmann