



Type Approval Certificate

[Fuse Links]

Initial Approval 4 January 2012
Manufacturer Mersen France SB S.A.S.
 15 Rue Vaucanson, 69720 Saint Bonnet de Mure, France
Product Description Ferrule Fuse-links (Type : FR10AM/GG without indicator)

Type	Rated Voltage (V)	Max. Rated Current (A)	Rated Breaking Capacity (kA)
FR10AM	690	12	120
	500	20	120
	400	25, 32	120
FR10GG	690	16	120
	500	25	120
	400	32	120

Approval Condition

- This approval is granted on the basis of the following documents.
 - Test report no. N81013-1~10, 810104-1~14, N826003-1~8, N810802-1~10, N810803-1~12, N826002-1~7, N826003-1~8, N835203-1~17.
- Individual Product Certification is not required.
- Manufacturing Place :
 - A. Mersen France SB S.A.S(France)
 - B. NOLAM Tunisia(Tunisia)

THIS IS TO CERTIFY that the above-mentioned product has been approved in accordance with the relevant requirement of this Society's Rules and / or of the recognized standards as follows.

Pt. 6, Ch. 1, Art. 802 of the Rules for Classification, Steel Ships, IEC 60269-1, IEC 60269-2

This Certificate is valid until 3 January 2027

Issued at Busan, Korea on 26 August 2022



This certificate is signed electronically in accordance with IMO FAL.5/Circ.39/Rev.2. Validation and authentication of the certificate can be confirmed from "http://e-cert.krs.co.kr" by using the tracking No(ME22024189648) and certificate No.(PAR27956-EL003).



KOREAN REGISTER

*General Manager of
Marine & Ocean Equipment Team*

Note :

- This certificate will be valid subject to complying with the approval conditions described on the certificate and/or on the Rules of this Society.
- This certificate will be invalid from the expiry date aforementioned unless the extension or renewal has been granted to the applicant or the manufacturer.
- Any significant modifications or changes in design or construction to the above product without approval from this Society will render this certificate invalid.
- Should the specified rules, regulations or standards be amended during the validity of this certificate, the product is to be re-approved by this Society in accordance with the requirements as amended.