



# 中国国家强制性产品认证证书

证书编号：2013010308612571

### 委托人名称、地址

美尔森电气保护系统(上海)有限公司  
上海市松江区书山路55弄6、7、8号

### 生产者(制造商)名称、地址

美尔森电气保护系统(上海)有限公司  
上海市松江区书山路55弄6、7、8号

### 生产企业名称、地址

美尔森电气保护系统(上海)有限公司  
上海市松江区书山路55弄6、7、8号

### 产品名称和系列、规格、型号

半导体设备保护用熔断体

□URD32□□□: Un: AC450V, AC500V, AC550V, AC600V, AC690V; In: 315A, 350A, 400A, 450A, 500A, 550A, 630A, 700A, 800A, 900A, 1000A /AC690V; 1100A /AC600V; 1250A/AC550V; 1400A, 1600A/AC500V; 1800A/AC450V; 额定分断能力: 100kA; 分断范围和使用类别: aR; 型号解释见附件

### 产品标准和技术要求

GB/T 13539.4-2016

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，  
特发此证。

发证日期：2018年05月16日 有效期至：2023年05月16日  
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2013年05月13日

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任：



## 中国质量认证中心



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2013010308612571

## NAME AND ADDRESS OF THE APPLICANT

Mersen Shanghai Co.,Ltd.  
No.6、7、8, Lane 55, Shushan Road, Songjiang District, Shanghai City, P.R.China

## NAME AND ADDRESS OF THE MANUFACTURER

Mersen Shanghai Co.,Ltd.  
No.6、7、8, Lane 55, Shushan Road, Songjiang District, Shanghai City, P.R.China

## NAME AND ADDRESS OF THE FACTORY

Mersen Shanghai Co.,Ltd.  
No.6,7,8, Lane 55, Shushan Road, Shanghai, P.R.China

## PRODUCT NAME, MODEL AND SPECIFICATION

Fuse-links for the protection of semiconductor devices

□URD32□□□: Un: AC450V, AC500V, AC550V, AC600V, AC690V; In: 315A, 350A, 400A, 450A, 500A, 550A, 630A, 700A,800A, 900A, 1000A /AC690V; 1100A /AC600V; 1250A/AC550V; 1400A, 1600A/AC500V; 1800A/AC450V; I1: 100kA; Breaking Range and Utilization Category: aR; See the appendix

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.4-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.16,2018      Valid until: May.16,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: May.13,2013

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



## CHINA QUALITY CERTIFICATION CENTRE



# 中国国家强制性产品认证证书


附录：

第 1 页 共 5 页

证书编号：2013010308612571

纸号：1718067

型号的解释：



xx	URD	32	xx	xx
电压/100 Voltage /100	曲线类型 Type of curve	陶瓷管尺寸 Size of body	端子 TTF-平端安装 ( 公制螺纹 ) TTI-平端安装 ( 英制螺纹 ) KI-美式安装 ( 短刀片 ) LI-美式安装 ( 长刀片 ) EF-勾型安装 ( E 向刀片 )	电流 Rating

注：此附录与证书同时使用时有效。



主任：



## 中国质量认证中心