



NIPPON KAIJI KYOKAI

Certificate of Type Test

Certificate No.

TA22356M

MANUFACTURER: Mersen France SB SAS, France

PRODUCT: Low voltage HRC Fuse-links
Cylindrical Fuse-links 14x51gG with or without striker

TYPE NO.: FR14GG69V, FR14GG50V

TYPE TEST NO.: 07T102

PARTICULARS: Rated voltage a.c. 690V, 500V
Rated current 1~50A at a.c.690V without striker
2~50A at a.c.500V with striker
Rated breaking capacity 120kA at a.c.690V, 500V

STANDARD: IEC60269-1 Ed.4.2(2014), IEC60269-2 Ed.5.1(2016)

DOCUMENTATION: A127846 A

THIS IS TO CERTIFY that the above mentioned product has been approved by the NIPPON KAIJI KYOKAI in accordance with the Society's type test requirements for electrical equipment and cables.

This certificate is valid until 26 September 2026.

Issued at Tokyo on 29 June 2022.

S. Oishi
General Manager
Machinery Department

Note: The manufacturer, if desired, is requested to apply to the Society for renewal prior to the expiration date.