



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **25214-005-06**

Valid from: 2020 07 02
until: 2022 07 02

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **Mersen France SB SAS**
15 Rue Jacques de Vaucanson
69720 Saint Bonnet de Mure
France

Product: **Low-voltage fuse-rails**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **2.03.02423.1.0/00.BSL, SGP-12376/00.BSL/100mm, SGP-12376/00.BSL/185mm**

Österreichischer Verband für Elektrotechnik
Head of Testing and Certification

Digitally signed by W. Martin
Email=w.martin@ove.at

Dipl.-Ing. W. Martin

Wien, 2020 05 26



OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.



Manufacturer:

Mersen France SB SAS
15 Rue Jacques de Vaucanson
69720 Saint Bonnet de Mure
France

Factory location(s):

Mersen CZ s.r.o.
Pardubická 437
53304 Sezemice
Czech Republic

Tested and certified according to:

ÖVE/ÖNORM EN 60269-1:2015-06-01
ÖVE/ÖNORM E 8669-2:2014-11-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**.

Product: Low-voltage fuse-rails

Type designation:

Rating:

Trademark:

00.BSL/100mm

Rated voltage: 690 V
Rated frequency: 50-60 Hz
Rated current: 160 A
Size 00;
3-pole
IP 20 (by using fuse-links with gripping lugs of insulating material)

MERSEN

00.BSL/185mm

Rated voltage: 690 V
Rated frequency: 50-60 Hz
Rated current: 160 A
Size 00;
3-pole
IP 20 (by using fuse-links with gripping lugs of insulating material)

MERSEN

OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.